

**ADDENDUM NO. 4
TO THE
BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS
FOR THE
WHITE RIVER INTERCEPTOR SEWER – PHASE IIA PROJECT**

OWNER: City of Anderson

ISSUED BY/ENGINEER: Beam, Longest and Neff, L.L.C.
8320 Craig Street
Indianapolis, Indiana 46250

ISSUED TO: All Plan and Specifications Holders of Record

ISSUE DATE: December 15, 2020

BID DATE: December 17, 2020

This Addendum No. 4 shall clarify, correct, or change the Bidding Requirements or the proposed Contract Documents. This Addendum is a part of the Bidding Requirements and the proposed Contract Documents and shall govern in the performance of the Work.

PART 1. PROJECT MANUAL

1.1 ITEM NO. 1 – 02530 GRAVITY SANITARY SEWERAGE

A. Add the following after 1.5.B.2.a:

- b. Design calculations must be sealed and certified by a Professional Engineer licensed in the State of Indiana for any cast in place structures.*
- c. Buoyancy calculations must be provided for all structures, precast or cast in place. Buoyancy calculations are not required to be stamped and signed by a Licensed Engineer.*

1.2 ITEM NO. 2 – 02530 GRAVITY SANITARY SEWERAGE

A. Revise section 3.8.E. Water Infiltration Tests:

- a. Replace all instances of 100 gal/in/mi/day maximum allowable infiltration with 200 gal/in/mi/day maximum allowable infiltration.*

PART 2. DRAWINGS – NO CHANGES

PART 3. ADDITIONAL TECHNICAL INFORMATION

The following technical information is not part of the Contract Documents, but Bidder is entitled to rely upon this information as provided in Paragraph 4.02 of the General Conditions. Bidder is responsible for any interpretation or conclusion Bidder draws from any “technical data” or any other data, interpretations, opinions, or information contained in such information.

3.1 SIGNED AND SEALED CALCULATIONS

- A. As further clarification signed and sealed calculations are required for cast in place structures, not precast structures that are produced to the quality and performance requirements contained in the project specifications. Buoyancy calculations are required for all structures and do not need to be signed and sealed by a licensed engineer.

Except as modified by this Addendum and other Addenda, the Bidding Requirements and the proposed Contract Documents shall remain unchanged. You will receive no other notification of this Addendum. **RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED IN SECTION 00410 - BID FORM, PAGE 00410-1.**

CERTIFIED BY:

Renee Lynn Goff, P.E.
Registered P.E. No. 10403860
State of Indiana

Enclosures: None