

**ADDENDUM NO. 5
TO THE
BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS
FOR THE
DIV IV DRY WEATHER PUMP STATION AND FORCE MAIN REHABILITATION**

OWNER: City of Anderson

ISSUED BY/ENGINEER: Egis Group
8320 Craig Street
Indianapolis, Indiana 46250

ISSUED TO: All Plan and Specifications Holders of Record

ISSUE DATE: July 18, 2025

BID DATE: July 22, 2025

This Addendum No. 5 shall clarify, correct, or change the Bidding Requirements or the proposed Contract Documents. This Addendum is a part of the Bidding Requirements and the proposed Contract Documents and shall govern in the performance of the Work.

PART 1 - PROJECT MANUAL - NONE

PART 2 – DRAWINGS - NONE

PART 3 – ADDITIONAL TECHNICAL INFORMATION

The following technical information is not part of the Contract Documents, but Bidder is entitled to rely upon this “technical data” as provided in Paragraph 5.02 of the General Conditions. Bidder is responsible for any interpretation or conclusion Bidder draws from any “technical data” or any other data, interpretations, opinions or information contained in such information.

3.1 ITEM NO. 3 – QUESTIONS

- A. Will Mag Meters and DO sensors be needed for project as described in spec section?

Response: No mag meters or DO sensors are required on this project.

- B. Is the Products List, Subcontractors List, and Schedule of Values to be included with the bid?

Response: Please see 00410 Article 2 2.02. These items are due within 5 days of request after bids are open, but are not required to be submitted with the bid to be considered responsive.

Encls.: None