

**ADDENDUM NO. 2
TO THE
BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS
FOR THE
LIBBERT ROAD WATER MAIN REPLACEMENT**

OWNER: Town of Chandler Utilities
401 E. Lincoln Avenue
Chandler, IN 47610

ISSUED BY/ENGINEER: Egis BLN USA, Inc.
8320 Craig Street
Indianapolis, Indiana 46250

ISSUED TO: All Plan and Specifications Holders of Record

ISSUE DATE: March 18th, 2026

BID DATE: April 6th, 2026

This Addendum No. 2, consisting of 2 pages, shall clarify, correct, or change the Bidding Requirements or the proposed Contract Documents. This Addendum is a part of the Bidding Requirements and the proposed Contract Documents and shall govern in the performance of the Work.

PART 1 - PROJECT MANUAL

1.1 - ITEM NO. 1 - SECTION 00410A – BID FORM ATTACHMENT A

- A. Bid Form Attachment A has been updated to include the allowance amount for Landscape Repairs for a total amount of up to \$50,000 as specified in the Allowances (Section 01210).

PART 2 - DRAWINGS - NONE

PART 3 - ADDITIONAL TECHNICAL INFORMATION

The following technical information is not part of the Contract Documents, but Bidder is entitled to rely upon this "technical data" as provided in Paragraph 4.02 of the General Conditions. Bid-der is responsible for any interpretation or conclusion Bidder draws from any "technical data" or any other data, interpretations, opinions or information contained in such information.

3.1 - ITEM NO. 1 - PRE-BID MEETING MINUTES

- A. Pre-bid Meeting minutes and Sign-in Sheet from the March 16th, 2026, Pre-Bid Meeting are attached to this addendum.

3.2 - ITEM NO. 2 - QUESTIONS AND REPOSENSE LIST NO. 1

- A. Questions and Responses List No. 1 is attached to this addendum and addresses questions received as of 5:00 PM March 17th, 2026.

Except as modified by this Addendum and other Addenda, the Bidding Requirements and the proposed Contract Documents shall remain unchanged. You will receive no other notification of this Addendum. **RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED IN SECTION 00410 - BID FORM, PAGE 00410-1.**

CERTIFIED BY:



Pete Wamsley, P.E.
Registered P.E. No. 11300326
State of Indiana



Encls.:

Pre-Bid Meeting Minutes (2026.3.16) – *Includes Sign-in Sheet*

Questions & Response List No. 1

00410A – Bid Form Attachment A

**QUESTIONS AND RESPONSES LIST NO. 1
FOR THE
LIBBERT ROAD WATER MAIN REPLACEMENT**

The following questions that did not warrant revisions to the Contract Documents have been presented by potential bidders for the **Libbert Road Water Main Replacement** Project. Responses to these questions are provided below. These questions and responses serve only to clarify the Bidding Documents and the Contract Documents, as applicable. The responses to these questions do not modify in any respect the conditions and provisions of the Contract Documents. In the event of a conflict between these responses and the Contract Documents, the provisions of the Contract Documents shall supersede these responses.

Q: You said the meter pits will be reused? Or just the meters?

R: Only the meters will be reused/relocated. None of the existing meter pits will be reused/relocated. Chandler will verify the ages of each of the meters being replaced and determine if any new meters will be needed. If any are needed, Chandler will provide them to the contractor.

Q: Is the existing main to be grout filled or cut and cap and abandon in place?

R: Cutting and capping the line and abandoning it in place is fine.

Q: What was the reason for the back tap at Vann Road?

R: There is a storm line on the north side of the road. The back tap will be made on the road side to be able to place the tapping sleeve & valve without interfering with or having to relocate that storm line.

Encl.:

NONE